

Use Case: OpenADR



Use Case:

C&I sites that change utility DR programs

- **Annually**
- **Seasonally**
- **Multiple Simultaneous**
- **Unknown future programs**

Requirement:

- **No change to onsite client required**
- **No change to onsite controls logic required**

Use Case: OpenADR



Shed Level	Program A	Program B	Program C (future)
Normal	No Change	No Change	No Change
Medium	3 X multiplier	\$0.40 / kWh	?
High	5 X multiplier	\$0.80 / kWh	??

Solution: Simple messages (levels) must be included for optional use.